

ARTICLE III
Treatment Capacity

- Section 1 The design capacity of the Town's wastewater treatment plant (WWTP) shall be limited to 750,000 gallons per day.
- Section 2 The allocated capacity of the WWTP shall be calculated on a periodic basis as determined by the Town Council but not less than once a calendar year.
- Section 3 This calculation shall include the following:
- (a) The average daily flow for the most recent twelve month period.
 - (b) Allocations for all undeveloped land within the corporate limits at current zoning.
 - (c) Allocations for all taps which have been approved but not yet connected.
 - (d) Allocations for any other taps which have been reserved by the Town.
- Section.4 Should the allocated capacity of the WWTP equal, or exceed 90% of the in-place treatment capacity, or in the event the Town is enjoined by State regulations, the Town shall not:
- (a) Accept new applications for out-of-town taps.
 - (b) Annex land, or otherwise adjust the Town boundary, to increase the number of in-town taps the Town would be required to reserve.
 - (c) Accept any new applications to re-zone property that would increase sewer capacity.